

**DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB**  
Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin  
code 152026  
dwtlmks@gmail.com

To: imperial public school  
sangudhon muktsar

No.: DWTL/MKS/2324/00001 Dated : 05/04/2023

Testing Reports of Water Samples.


Subject :

Reference:

Your Letter/SRF No. 2120 Dated: 03/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s  
received on dated 03/04/2023. It is request to fill the attached feedback form and send it back to District Water  
Testing Laboratory, Sh. Muktsar Sahib

/A: Test Report



Authorized Signatory  
For, District Water Testing Laboratory, Sh.  
Muktsar Sahib



Principal  
**Imperial Public School**  
Senior Secondary School  
Sri Muktsar Sahib

Name & Address of Customer :  
 imperial public school  
 sangudhon muktsar

**TEST REPORT**

Customer Reference No : No : 2120 Dated : 03/04/2023  
 Sample Submitted by : Principal  
 Date of Sample Receipt : 03/04/2023  
 Analysis Starting Date : 03/04/2023  
 Analysis completion Date : 04/04/2023

Discipline : Chemical Testing


ULR No.: TC99772300000077F  
 Test Report No.: DWTL/MKS/2324/00001  
 Registration no.: DWTL/MKS/REG2324/00001  
 Collection Point: Treatment Plant  
 (RO/CWPP/ARP/HH Purifier)  
 Scheme/Source: Not Mentioned(Not Mentioned)  
 Village : Sangu Dhon  
 Block: Muktsar  
 Latitude : Not Mentioned


Group: Water  
 Sample Type: Water  
 Date of Issue: 05/04/2023  
 Condition of Sample: Sealed  
 Quantity/Type of Bottle: 1000 ml / Amber Colored Glass Bottle  
 Location/Depth :  
 Habitation : sangu dhon / NA  
 District : Sangu Dhon  
 Longitude: Muktsar  
 Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.92	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	2.0	5	15	--	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 1984) (RA 2017)
5	TDS	130	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.8	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	68	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	76	200	600	mg/l	IS 3025 (Part 21-2019) EDTA Method
9	Calcium	18	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	8	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg-2 B. By Calculation Method
11	Chloride	34	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

  
**Imperial Public School**  
**A Senior Secondary School**  
**Sri Muktsar Sahib**

  
**Mr. Pardeep kumar**  
**Quality Manager**  
**Authorized Signatory**  
**For, District Water Testing Laboratory, Sh.**  
**Muktsar Sahib**

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB  
Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin code 152026  
dwtlmks@gmail.com

INVOICE

Bill No. : INV/2324/00005

Date. : 03/04/2023

To, imperial public school  
sangudhon muktsar  
Ref. : Letter No. 2120 Dt. 03/04/2023


Sample Receiving No. DWTL/MKS/R2324/00005 Dt.  
03/04/2023

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Sangu Dhon, sangu dhon	Water	Private Schools	Basic Chemical : Calcium, Alkalinity, TDS, Odour, pH, Magnesium, Hardness, Turbidity, Chloride, Taste, Colour	1	130.00	130.00
Total							130.00

Payment Mode : Cash  
Payment Status : PAID  
One Hundred Thirty Only.  
STR No. : NA

Note:- \* Discount applicable as per Government Notification Number : No 9284 & Date : 09/11/2021

Authorised Signatory

  
Imperial Public School  
A Senior Secondary School  
Sri Muktsar Sahib